


THIS REPORT TO BE SUBMITTED
WITHIN 60 DAYS AFTER WELL
COMPLETION, TO:

CONTROLLER OF WATER RESOURCES
ALBERTA ENVIRONMENT
OXBRIDGE PLACE, EDMONTON



(1) WELL CONTRACTOR		(8) WELL OWNER		(16) LOCATION																																								
PARSONS DRILLING Address BOX 160 CREMONA, ALBERTA TOM ORO		LEVINSON CONSULTING LTD. Address 450. 640-17th. S.W. CALGARY.		1/4	Sec.	Twp.	Rge.	West of Meridian																																				
				SW	13	24	3	5																																				
				SPRINEBANK. Mark Well location with an "X" in diagram below																																								
(2) License No. 0057. Permit No. 68. Date started FEB 5 19 79 Date completed FEB 19 19 79		(9) WELL COMPLETION DATA DESIGN: Open hole ☐ Slotted casing ☒ Screen ☐ Gravel pack ☐ Diameter of hole: 8" TO 4 7/8" Bottomed in: Clay ☐ Sand ☐ Sandstone ☒ Shale ☐ Coal ☐ Depth to top of bedrock: 86 FT Total depth: 94 FT.		NW NE SW SE 1 SQUARE MILE																																								
(3) TYPE OF WELL: Rotary ☐ Bored ☐ Cable tool ☒ Jet ☐ Dug ☐ Other ☐		(10) CASING: Type: 6 5/8 STEEL. Size O. D. 6 5/8 Wall thickness: 188 Wt. per ft. 13.0. Bottom set at: 85.6 ft.																																										
(4) TYPE OF WORK: New Well ☒ Deepen ☐ Recondition ☐ Abandon ☐		(11) SEAL: Yes ☒ No ☐ Packer ☐ Grout ☐ Driven ☒ Loose ☐ Puddled clay ☐ DRIVE SHOE. Depth of seal: 85.6																																										
(5) PROPOSED USE: Domestic ☐ Stock ☐ Irrigation ☐ Municipal ☒ Industrial ☐ Test ☐		(12) LINER: Yes ☒ No ☐ Type: 5" STEEL. Size O.D. 5" I. D. 4 9/16 Weight: 8.07 lbs. Bottom set at: 94. ft. Perforated from: 85 ft. to 93 ft. How perforated: Knife ☐ Torch ☒ Machine ☐ Size perforations: 3/8 in. by 16 in.		(17) WATER QUALITY: Hard ☐ Medium Hard ☒ Soft ☐ Turbid ☐ Chemical Analysis: Yes ☒ No ☐ Bacterial Analysis: Yes ☐ No ☒																																								
(6) FORMATION LOG DESCRIPTION		(13) SCREEN: Yes ☐ No ☒ Make: Material: Size I. D. (clear): Length: Slot size: Top at: Bottom at: Fittings top: Fittings bottom:		(18) WATER TEST: Pump ☒ Bailer ☐ Static water level 56.01 FT. Rate of yield: 10 I. G. P. M. Duration of test: 48 hrs. - min. Pumping level or bailing level: 56.01. Total drawdown at end of test: 3 1/2 INCHES. Pump setting: ft. 90 10 I.G.P.M. Additional Yield Test Information Attached (Yes/No) (Yes)																																								
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width:10%;">Depth in Feet</th> <th style="width:10%;">from</th> <th style="width:10%;">to</th> <th style="width:70%;">Use key to formation</th> </tr> </thead> <tbody> <tr> <td>Ground Level</td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td>28</td> <td></td> <td>YELLOW CLAY.</td> </tr> <tr> <td></td> <td>28</td> <td>44</td> <td>SOFT GREY SHALE</td> </tr> <tr> <td></td> <td>44</td> <td>49</td> <td>FIRM SHALE</td> </tr> <tr> <td></td> <td>49</td> <td>57</td> <td>SOFT SHALE</td> </tr> <tr> <td></td> <td>57</td> <td>63</td> <td>SILTY SHALE</td> </tr> <tr> <td></td> <td>63</td> <td>86</td> <td>GRAVELY SAND</td> </tr> <tr> <td></td> <td>86</td> <td>94</td> <td>HARD BRN. S.S.</td> </tr> </tbody> </table>		Depth in Feet	from	to	Use key to formation	Ground Level					28		YELLOW CLAY.		28	44	SOFT GREY SHALE		44	49	FIRM SHALE		49	57	SOFT SHALE		57	63	SILTY SHALE		63	86	GRAVELY SAND		86	94	HARD BRN. S.S.	(14) SAND PACK: Yes ☐ No ☒ Size Amount:		(19) WATER WELL DRILLER (operator) This well was constructed under my direct supervision and all information given is true to the best of my knowledge and belief. A copy of this report has been supplied to the owner. Signature: R O Parsons Date: Feb 26 19 79				
Depth in Feet	from	to	Use key to formation																																									
Ground Level																																												
	28		YELLOW CLAY.																																									
	28	44	SOFT GREY SHALE																																									
	44	49	FIRM SHALE																																									
	49	57	SOFT SHALE																																									
	57	63	SILTY SHALE																																									
	63	86	GRAVELY SAND																																									
	86	94	HARD BRN. S.S.																																									
(7) ELECTRIC LOG: Yes ☐ No ☒		(15) PUMP: Yes ☐ No ☒ Type: H. P. Size: Voltage: Drop pipe size: Length:		(20) WELL OWNER Anticipated Use 10000 gal. per day I have received a copy of this report. Signature: [Signature] Date: Feb 27 19 79																																								